

General safety and security guide

Hervannan kampus, Sähkötalo

EMERGENCY TELEPHONE NUMBER AND POLICE

112

BUILDING ADDRESS

Korkeakoulunkatu 3
33720 TAMPERE

IN CASE OF FIRE

1. **RESCUE** those in immediate danger.
2. **NOTIFY** others of danger.
3. **MAKE AN ALERT**. Call 112.
4. **EXTINGUISH** the fire, if you can.
5. **CONFINE**. Close all windows and doors.
6. **GUIDE** the officials to the site.

LIFT

Do not use the lift in the event of fire.

PUBLIC WARNING SIGNAL

1. Move indoors, stay indoors.
2. Close doors, windows, ventilation holes, and air conditioning devices.
3. Open the radio and calmly wait for instructions.
4. Avoid using the telephone
5. Do not leave the areas unless urged to do so by the authorities, so as not to endanger yourself on the way.

RESCUE PLAN

The rescue plan can be found from the address:

<https://tuni.pelsu.fi/tuni-sahkotalo/>

GATHERING AREA

Tietotalo buildings parking area on the west side of the Sähkötalo building, behind the Tietotalo building

BACK-UP GATHERING AREA

-

ELECTRICITY SWITCHBOARD

Four main distribution boards: 1. floor A-section room SA109, F-section rooms SF101 and SF116C, and M-section room SM137

MAIN WATER SHUTOFF

In basement floor A-Section heat distribution room SA007

GAS SHUT-OFF

Nitrogen main shut valve in 1. floor E-section corridor SE100E

AIR VENTILATION EMERGENCY STOP

1. floor F-section in room SF116B, N-section in laboratory SN101 and J-section in draught lobby SJ112A

FIRE ALARM

The property has six fire alarm central panels in total: 1. floor A-section in lobby/corridor area SA105 (2 units) and F-section in room SF116A, 2. floor C-section in corridor SC200B, G-section in corridor SG200B and L-section in room L200.1

CIVIL DEFENCE SHELTERS

This property has 2 civil defence shelters.

1. floor M-section room SM121
1. floor M-section room SM111

The property has a civil defence shelter at the addresses:

Korkeakoulunkatu 1, Tietotalo building

Korkeakoulunkatu 5, Kalliosuoja (Bommari)
Korkeakoulunkatu 7, Kampusareena